



Tradesman
Heating & Air Conditioning

GOODMAN

DIAGNOSTIC CODES

CODES	DESCRIPTION
Steady on	Normal operation
OFF	Control Failure
1 Flash	System lockout (Retries exceeded)
2 Flashes	Pressure switch stuck closed
3 Flashes	Pressure switch stuck open
4 Flashes	Open high limit
5 Flashes	Flame sense without gas valve
6 Flashes	Open rollout or open fuse
7 Flashes	Low flame signal
Continuous/Rapid Flashes	Reversed 115 vac polarity